



601 N. Moapa Valley Boulevard * Post Office Box 257
Logandale, Nevada * 89021
Telephone (702) 397-6893 * Facsimile (702) 397-6894

To: Chairman Ken Staton, & MVWD Board of Directors

From: Joseph Davis, General Manager

Date: August 1, 2016

Subject: Purchase of a Backup Power Generator

Background:

The District advertised in the Review Journal for requests for bids on a 350kW or 400kW Standby Power System for the Arrow Canyon well site. Only one bid was received by the July 13, 2016 deadline.

GEN-TECH of Nevada, 400kW unit in the amount of \$64,460

This is an industrial outdoor diesel generator set rated at 400kW with a built in 693 gallon double walled fuel tank capable of running 25 hrs at 100% power rated load output. The unit is capable of performing all the District's power generation needs for the Arrow Canyon well site.

The bid amount is well below the District budgeted amount of \$80,000.00. Staff recommends accepting the bid from GEN-TECH of Nevada

Suggested Motion:

Move to accept the bid from GEN-TECH of Nevada, INC. for a Generac SD400 Diesel Generator in the amount of \$64,460.